

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
07/12/2011	ADP003	7.37	3.5	2.6	1.5	4.2	0.29	5.26	0.215	10
14/12/2011	ADP003	7.5	2.5	2.3	1.1	1	0.279	4.71	0.574	10
21/12/2011	ADP003	7.37	2	1.2	1.2	2.1	0.34	5.22	0.645	10
28/12/2011	ADP003	7.21	5	3.6	2	0.7	0.31	6.2	0.488	10
04/01/2012	ADP003	7.2	4.5	3.2	1.3	0.5	0.42	5.97	0.579	10
11/01/2012	ADP003	7.1	3.5	2.1	1.6	5.1	0.5	3.89	0.533	10
18/01/2012	ADP003	6.95	0.5	<0.5	0.7	1.8	0.15	2.93	0.063	16000
25/01/2012	ADP003	7.15	5.5	4.2	1.2	3.9	0.28	2.06	0.067	70
01/02/2012	ADP003	6.93	2.5	2.3	5.4	0.6	0.18	4.22	0.013	22000
08/02/2012	ADP003	7.28	0.5	0.5	1	3.3	0.13	5.03	0.439	10
15/02/2012	ADP003	6.78	0.5	<0.5	1	0.6	0.19	5.36	0.205	40
22/02/2012	ADP003	7.11	0.5	<0.5	0.5	2.1	0.17	2.92	0.14	10
29/02/2012	ADP003	7.39	0.5	<0.5	1.1	0.5	0.27	5.42	0.248	1400
07/03/2012	ADP003	6.99	2.5	<0.5	1	0.8	0.23	3.76	0.313	10
14/03/2012	ADP003	7.35	1.5	1.2	0.8	0.5	0.23	6.32	0.206	10
21/03/2012	ADP003	7.77	0.5	<0.5	1.2	2.9	0.41	3.15	0.477	10
28/03/2012	ADP003	7.23	3.5	2.9	1.1	1.1	0.33	4.12	0.597	10
04/04/2012	ADP003	7.2	1.5	0.5	1	5.5	0.21	5.03	0.291	<10
11/04/2012	ADP003	7.08	3	2.8	1	0.5	0.19	4.84	0.297	<10
18/04/2012	ADP003	7.1	3	2.2	1.6	0.9	0.2	2.88	0.284	80
25/04/2012	ADP003	7.26	4	3.9	1	0.5	0.14	5.52	0.663	20
02/05/2012	ADP003	7.31	5.5	5	1.2	3.7	0.3	3.59	0.337	10
09/05/2012	ADP003	7.69	2.5	1.9	1.1	2.8	0.18	5.97	0.732	20
16/05/2012	ADP003	7.56	1	0.8	1.3	3.4	0.11	5.71	0.591	10
23/05/2012	ADP003	7.28	2.5	2.3	5	4	0.075	7.12	0.013	80000
30/05/2012	ADP003	7.21	3	2.8	4.2	<0.5	0.1	2.75	0.539	21000
06/06/2012	ADP003	7.41	5.5	5.3	1.6	1.9	0.22	4.24	0.303	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
13/06/2012	ADP003	7.87	18	17.2	3.6	2	0.45	2.77	0.213	390
20/06/2012	ADP003	7.83	3.5	3.3	1.4	2.3	0.15	6.63	0.376	<10
27/06/2012	ADP003	7.47	3.5	3.1	1.4	7.4	0.165	7.06	0.291	<10
04/07/2012	ADP003	7.05	7	6.8	1.6	2	0.27	7.05	0.302	<10
11/07/2012	ADP003	7.08	0.5	0.1	1.1	3.5	0.09	5.93	0.627	10
18/07/2012	ADP003	7.3	1	0.3	0.9	2.3	0.068	7.01	0.2	<10
25/07/2012	ADP003	7.46	13.5	11.8	2.9	1.1	0.35	4.74	0.384	10
01/08/2012	ADP003	7.41	17.5	15.8	4.2	1.5	0.54	2.97	0.103	20
08/08/2012	ADP003	7.1	2.5	1.4	3.1	3.1	0.17	3.31	0.428	10
15/08/2012	ADP003	7.56	2	1.8	1.7	<0.5	0.18	5.19	0.553	<10
22/08/2012	ADP003	7.65	47	45.8	6.9	22.2	1.01	5.54	0.252	<10
29/08/2012	ADP003	7.54	4	3.2	2.4	4.3	0.27	3.57	0.811	50
05/09/2012	ADP003	7.46	4.5	4.3	3.1	<0.5	0.54	4.81	0.804	20
12/09/2012	ADP003	7.56	1	0.5	2.9	2.9	0.32	4.24	0.873	10
19/09/2012	ADP003	7.54	2.5	2.1	5.9	3.2	0.3	4.02	1.004	10
26/09/2012	ADP003	7.52	2.5	2.2	2.1	4.7	0.9	5.13	0.469	<10
03/10/2012	ADP003	7.44	4.5	3.4	1.2	3.5	0.23	5.06	0.069	40
10/10/2012	ADP003	7.65	<0.5	<0.5	1.3	1.2	0.25	4.34	0.875	130
17/10/2012	ADP003	7.5	5	4.7	1.5	3.5	0.38	4.55	0.509	720
24/10/2012	ADP003	7.57	6.5	5.9	1.7	<0.5	0.36	5.3	0.857	10
31/10/2012	ADP003	7.44	4	3.6	2.5	11.9	0.73	6.29	1.641	40
07/11/2012	ADP003	7.29	<0.5	<0.5	1.9	0.6	0.52	4.4	1.338	20
14/11/2012	ADP003	7.39	19	18.6	9.2	1.5	1.37	5.89	0.649	10
21/11/2012	ADP003	7.23	3.5	3.3	1	2	0.2	7.25	0.334	50
28/11/2012	NOTE: ADP001	7.53	1	<0.5	2	5.1	0.07	3.23	0.195	47000
05/12/2012	ADP003	7.52	2	1.5	1.3	23.6	0.19	3.51	0.416	30
12/12/2012	ADP003	7.55	0.5	<0.5	0.9	4.5	0.12	4.66	0.828	10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
19/12/2012	ADP003	7.53	14	13.4	2.1	1	0.52	4.3	0.711	10
26/12/2012	ADP003	7.35	15	14.5	3.2	1.1	0.59	4.76	0.514	<10
02/01/2013	ADP003	7.37	3	2.8	1.1	1.3	0.15	3.17	0.029	10
09/01/2013	ADP003	7.46	1.5	1.2	3.1	2	0.12	3.05	0.238	54000
16/01/2013	NOTE: ADP001	7.39	1	0.5	4.2	<0.5	0.31	4.1	1.349	90000
23/01/2013	NOTE: ADP001	7.22	<0.5	<0.5	4.7	5.1	0.09	3.95	0.092	14000
30/01/2013	NOTE: ADP001	7.12	2	1.8	1.7	1.8	0.19	3.72	0.179	36000
06/02/2013	ADP003	7.58	1	0.7	1.1	2	0.13	7.42	0.473	<10
13/02/2013	ADP003	7.59	2.5	2.2	1.3	<0.5	0.19	5.35	0.4	<10
20/02/2013	ADP003	7.26	1.5	1.3	1.1	0.8	0.24	3.14	0.505	<10
27/02/2013	ADP003	7.28	2.5	2.3	5.1	3.7	0.39	5.79	2.29	550
06/03/2013	ADP003	7.08	<0.5	<0.5	2.3	2.4	0.77	6.09	0.284	9000
13/03/2013	ADP003	7.41	1.5	0.7	1.4	1.8	0.2	5.2	0.357	20
20/03/2013	ADP003	7.45	6	5.1	1.4	1.6	0.23	5.4	0.266	<10
27/03/2013	ADP003	7.55	3	2.2	3	3.9	0.15	3.81	0.281	60
03/04/2013	ADP003	7.45	1	0.2	0.8	<0.5	0.22	4.86	0.706	10
10/04/2013	ADP003	7.51	2.5	1.7	1	<0.5	0.26	5.07	0.443	220
17/04/2013	ADP003	7.26	7	6.2	1.9	3.1	0.52	8.96	0.899	10
24/04/2013	ADP003	7.4	<0.5	<0.5	1.3	1.4	0.12	5.23	0.167	170
01/05/2013	ADP003	7.17	2	1.4	0.9	<0.5	0.16	5.13	0.374	10
08/05/2013	ADP003	7.64	1	<0.5	1.8	5.6	0.29	6.66	1.02	40
15/05/2013	ADP003	7.74	0.5	<0.5	0.7	1.4	0.41	4.02	0.366	<10
22/05/2013	ADP003	7.47	0.5	<0.5	1.1	3	0.52	6.28	1.188	<10
29/05/2013	ADP003	7.52	2	1.2	1	1.8	0.33	5.42	0.577	<10
05/06/2013	ADP003	7.6	2	1.5	1.3	<0.5	0.79	5.47	0.355	10
12/06/2013	ADP003	7.32	2.5	2	1.5	1.6	0.81	3.67	0.593	<10
19/06/2013	ADP003	7.22	3	2.8	1.7	<0.5	0.43	5.73	0.725	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
26/06/2013	ADP003	7.34	2.5	1.9	1.3	4.7	0.17	5	0.587	<10
03/07/2013	ADP003	6.79	2	1.3	4.6	2.7	0.26	2.96	0.039	14000
10/07/2013	ADP003	7.49	1	<0.5	1.1	<0.5	0.26	7.3	0.517	10
17/07/2013	ADP003	7.54	1	<0.5	0.9	0.6	0.13	5.45	0.3	<10
24/07/2013	ADP003	7.46	7	5.1	1.4	2.4	0.18	6.83	0.885	<10
31/07/2013	ADP003	7.48	2.5	2	1.2	0.9	0.15	5.08	0.619	<10
07/08/2013	ADP003	7.68	3	2.4	0.9	0.9	0.14	4.61	0.39	<10
14/08/2013	ADP003	7.44	4.5	3.7	1.6	<0.5	0.31	4.96	0.62	<10
21/08/2013	ADP003	7.48	3	2.8	0.7	3	0.2	5.59	0.321	<10
28/08/2013	ADP003	7.29	3	2.6	2.5	1	0.07	4.04	0.015	27000
04/09/2013	ADP003	7.36	1	0.6	0.8	3.9	0.16	5.52	0.639	10
11/09/2013	ADP003	7.41	1.5	1.2	2.6	2.3	0.28	3.95	0.751	<10
18/09/2013	ADP003	7.2	8	7.7	3.3	2	0.47	2.14	0.272	10
25/09/2013	ADP003	7.49	10.5	10.3	2.9	<0.5	0.35	3.98	0.351	10
02/10/2013	ADP003	7.09	2.5	2.3	1.5	1	0.239	3.985	0.282	<10
09/10/2013	ADP001	7.13	1	0.9	0.9	0.8	0.05	2.99	0.365	10000
16/10/2013	ADP001	7.3	2.5	2.3	0.8	<0.5	0.04	3	0.034	10500
23/10/2013	ADP003	7.27	1	0.99	1.9	5.1	0.12	3.57	0.409	20000
30/10/2013	ADP003	7.53	2.5	2.3	1	1.2	0.16	3.97	0.126	<10
06/11/2013	ADP003	7.19	12.5	12	2.4	1	0.55	3.49	0.013	20
13/11/2013	ID TANK	7.07	1.5	1.3	4.1	1.9	0.24	6.56	1.217	36000
20/11/2013	ADP003	7.3	<0.5	<0.5	0.9	0.8	0.25	4.37	0.783	<10
27/11/2013	ADP003	7.31	1	0.5	0.9	0.9	0.22	5.3	0.278	<10
04/12/2013	ADP003	7.37	2.5	1.8	0.9	1.4	0.43	4.53	0.324	<10
11/12/2013	ADP003	7.42	<0.5	<0.5	0.7	2.6	0.25	5.16	0.356	<10
18/12/2013	ADP003	7.45	1	0.7	0.9	1.3	0.18	5.12	0.229	10
24/12/2013	ADP003	7.31	2	1	1.3	<0.5	0.233	4.833	0.256	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
02/01/2014	ADP003	7.15	<0.5	<0.5	0.8	1.6	0.465	4.814	0.575	<10
08/01/2014	ADP003	7.51	2	1.1	1	<0.5	0.523	4.875	0.386	30
15/01/2014	ADP003	7.41	1.5	0.9	0.7	2.4	0.71	4.59	0.288	<10
22/01/2014	ADP003	7.56	<0.5	<0.5	1.3	1	0.6	4.66	0.436	<10
29/01/2014	ADP003	7.48	6	4.5	2.2	1	1.17	4.98	0.898	<10
05/02/2014	ADP003	7.19	2.5	1.8	1.1	1.5	0.52	5.4	0.364	<10
12/02/2014	ADP003	7.5	4.5	3.7	1.3	<0.5	0.3	4.66	0.433	10
19/02/2014	ADP003	7.39	4	3.6	1.2	2.9	0.24	4.7	0.192	<10
26/02/2014	ADP003	7.42	1.5	1	0.9	<0.5	0.2	4.78	0.255	<10
05/03/2014	ADP003	7.21	<0.5	<0.5	1.2	<0.5	0.21	4.85	0.216	<10
12/03/2014	ADP003	7.59	4	3.1	0.95	<0.5	0.19	4.16	0.135	<10
19/03/2014	ADP003	7.23	<0.5	<0.5	1.3	0.6	0.17	4.22	0.225	<10
26/03/2014	ADP003	7.24	1	<0.5	1.7	0.7	0.2	6.87	0.88	10
02/04/2014	ADP003	7.08	<0.5	<0.5	0.87	9.7	1.03	7.46	0.776	<10
09/04/2014	ADP003	7.44	1	<0.5	1	3.4	0.12	4.65	0.346	<10
16/04/2014	ADP003	7.28	<0.5	<0.5	0.7	4.7	0.1	5.58	0.332	<10
23/04/2014	ADP003	7.48	1.5	1.1	1.3	1.4	0.13	6.01	0.482	10
30/04/2014	ADP003	7.08	0.5	<0.5	1.2	2.8	0.11	6.11	0.541	20
07/05/2014	ADP003	7.13	0.5	<0.5	0.8	4.3	0.09	6.52	0.625	10
14/05/2014	ADP003	7.01	<0.5	<0.5	1.1	2.7	0.11	5.47	0.402	<10
21/05/2014	ADP003	7.14	1	<0.5	0.8	3.1	0.19	5.05	0.236	<10
28/05/2014	ADP003	6.94	1.5	<0.5	1.9	<0.5	0.55	3.58	0.889	<10
04/06/2014	ADP003	7.09	2.5	1.5	1.6	1.6	0.15	3.81	0.482	<10
11/06/2014	ADP003	6.97	0.5	<0.5	1.7	<0.5	0.18	3.79	0.371	<10
18/06/2014	ADP003	6.89	2.5	1.5	1.2	3.8	0.31	5.321	0.378	<10
25/06/2014	ADP003	6.56	2.5	2.2	1.5	<0.5	0.72	4.34	0.426	<10
02/07/2014	ADP003	7.12	3	2.4	1	1.6	0.866	5.45	0.041	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
09/07/2014	ADP003	7.38	5.5	5.2	1.9	0.9	0.26	6.08	0.292	<10
16/07/2014	ADP003	7.19	2	1.5	1.9	<0.5	0.4	5.75	0.981	530
23/07/2014	ADP003	7.42	<0.5	<0.5	2.6	4.9	0.5	4.83	0.526	<10
30/07/2014	ADP003	7.42	4.5	3.9	2.7	1.6	1.06	3.28	1.345	<10
06/08/2014	ADP003	7.03	0.5	<0.5	1.5	<0.5	0.16	2.33	0.054	18000
13/08/2014	ADP003	7.23	<0.5	<0.5	1.4	5.8	1.18	5.68	0.789	<10
20/08/2014	ADP003	6.99	5	4.7	1.9	1.4	0.83	5.11	0.384	<10
27/08/2014	ADP003	6.45	<0.5	<0.5	1.2	1.4	0.95	3.53	0.05	36000
03/09/2014	ADP003	6.86	4	3.5	5.6	<0.5	1.04	8.55	1.776	3600
10/09/2014	ADP003	6.93	<0.5	0	1.4	1.5	0.42	8.53	0.75	180
17/09/2014	ADP003	7.2	1.5	1.3	1.7	3	0.52	7.33	1	70
24/09/2014	ADP003	7.05	1.5	1.3	2.8	0.6	0.658	6.58	0.921	<10
01/10/2014	ADP003	7.01	1.5	1.3	2.3	<0.5	0.75	5.97	0.678	100
08/10/2014	ADP003	7.32	3	2.6	1.4	2.8	1.15	5.11	0.457	10
15/10/2014	ADP003	7.15	0.5	<0.5	1.3	3.5	2.12	5.29	0.055	18000
22/10/2014	ADP003	8.02	6.5	5.9	2.4	3.2	0.43	7.14	0.222	<10
29/10/2014	ADP003	7.05	2	1.8	1	<0.5	1.33	5.56	0.073	18000
05/11/2014	ADP003	7.64	<0.5	<0.5	1.1	3.5	0.49	4.24	0.212	6500
12/11/2014	ADP003	7.92	1.5	<0.5	1.1	<0.5	0.87	6.35	0.476	<10
19/11/2014	ADP003	8.01	3	2.2	2.4	1.4	0.83	5.33	0.379	<10
26/11/2014	ADP003	7.92	8.5	4.8	2.2	3.5	1.21	2.82	0.395	20
03/12/2014	ADP003	7.61	0.5	<0.5	3.9	<0.5	0.75	5.01	0.555	54000
10/12/2014	ADP003	7.67	5.5	5	3.7	4.6	0.97	4.22	0.394	9000
17/12/2014	ADP003	7.72	9	8.5	1.7	1.8	1.91	4.93	0.615	10
24/12/2014	ADP003	7.51	0.5	0	1.6	1.9	0.93	6.99	0.865	<10
31/12/2014	ADP003	7.03	1.5	0.9	1.2	1.1	1.552	7.11	0.682	<10
07/01/2015	ADP003	7.68	<0.5	<0.5	2.2	3.8	1.4	7.46	1.006	108000

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
14/01/2015	ADP003	7.68	4	3.1	1.6	0.7	0.73	5.58	0.315	120
21/01/2015	ADP003	7.61	3	2	1.7	2.3	0.41	7.31	0.394	3600
28/01/2015	ADP003	7.46	8	6.1	3.3	2.5	1.21	6.4	1.293	40
04/02/2015	ADP003	7.51	3	2.3	2.4	1.9	0.24	3.84	0.625	5000
11/02/2015	ADP003	7.67	4.5	2.1	1.9	5.1	0.72	4.29	1.943	150
18/02/2015	ADP003	7.65	3	2.6	1.5	0.9	0.58	5.51	0.593	220
25/02/2015	ADP003	7.58	8.5	7.9	4.5	3.4	0.37	7.69	1.194	9000
04/03/2015	ADP003	7.63	1	<0.5	1.9	6.4	0.71	12.82	1.897	10
11/03/2015	ADP003	7.64	<0.5	<0.5	1.6	2.8	0.44	5.34	0.641	30
18/03/2015	ADP003	7.6	3	1.8	1.6	3.4	0.56	7.46	0.782	20
25/03/2015	ADP003	7.67	7.5	6.2	2.2	1.6	1.24	4.471	0.366	200
01/04/2015	ADP003	7.56	2	1.1	1.9	3.6	0.71	4.66	0.904	460
08/04/2015	ADP003	7.4	0.5	<0.5	1.1	2.2	0.59	7.14	0.495	30
15/04/2015	ADP003	7.53	1.5	1	1.2	<0.5	0.44	7.41	0.278	<10
22/04/2015	ADP003	7.54	<0.5	<0.5	1	3	0.61	7.99	0.971	20
29/04/2015	ADP003	7.34	3	2.2	1.6	<0.5	0.34	4.56	0.357	20
06/05/2015	ADP003	7.49	2	0.5	3.4	1.3	0.58	5.78	0.608	400
13/05/2015	ADP003	7.58	1	0.6	1.8	1.4	0.37	7.32	1.118	5400
20/05/2015	ADP003	7.59	3	1.9	1.1	2.7	0.28	9.99	0.552	10
27/05/2015	ADP003	7.56	<0.5	<0.5	2.2	1	0.35	5.03	0.037	500
03/06/2015	ADP003	7.55	<0.5	<0.5	0.86	3.7	0.05	4.65	0.05	5400
10/06/2015	ADP003	7.68	1.5	1.3	1.6	<0.5	0.41	5.92	0.346	60
17/06/2015	ADP003	7.66	3.5	3	1.8	1.4	0.74	5.43	0.683	540
24/06/2015	ADP003	7.65	1.5	0.8	1.9	2.2	0.213	6.312	0.368	270
01/07/2015	ADP003	7.61	2	1.8	2	2	0.9	6.25	0.449	240
08/07/2015	ADP003	7.59	1	<0.5	2.1	<0.5	1.35	6.59	0.297	<10
15/07/2015	ADP003	7.59	0.5	<0.5	1.5	3.1	0.43	8.47	0.96	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
22/07/2015	ADP003	7.53	2	<0.5	2.3	4	0.37	7.99	0.861	<10
29/07/2015	ADP003	7.48	1	<0.5	1.5	2.8	0.61	7.77	1.302	<10
05/08/2015	ADP003	7.47	5	3.6	2.9	2.1	0.57	7.58	1.152	<10
12/08/2015	ADP003	7.63	1.5	<0.5	2.2	<0.5	0.39	7.37	1.065	10
19/08/2015	ADP003	7.75	1.5	1	1.7	8	0.37	6.12	1.061	10
26/08/2015	ADP003	7.58	5.5	4.6	2.2	1.2	0.43	3.81	0.606	<10
02/09/2015	ADP003	7.5	2	1.4	1.8	2.4	0.72	7.16	0.981	<10
09/09/2015	ADP003	7.22	0.5	<0.5	1.58	1.5	0.71	6.82	0.729	10
16/09/2015	ADP003	7.65	5	4.3	1.8	5.3	0.7	5.65	0.326	10
23/09/2015	ADP003	7.47	1	0.7	1.2	2.6	0.59	4.73	0.384	<10
30/09/2015	ADP003	7.51	<0.5	<0.5	2.2	<0.5	0.51	4.97	0.439	<10
07/10/2015	ADP003	7.57	4.5	3.6	2.2	5.2	0.54	6.63	0.374	<10
14/10/2015	ADP003	7.62	6	2.8	3	1.8	0.57	3.68	0.683	<10
21/10/2015	ADP003	7.46	0.5	<0.5	1.6	0.7	0.66	5.43	0.576	<10
28/10/2015	ADP003	6.89	1.5	0.9	3.9	4.5	1.37	5.08	1.618	54000
04/11/2015	ADP003	7.23	1	<0.5	2.1	2	0.26	6.87	0.929	72000
11/11/2015	ADP003	7.5	3.5	1.4	1.4	5	0.75	4.56	0.228	10
18/11/2015	ADP003	7.78	7	2.1	3.1	<0.5	0.31	3.27	0.285	10
25/11/2015	ADP003	7.22	4	3.3	1.4	0.7	0.32	3.21	0.559	<10
02/12/2015	ADP003	7.71	<0.5	<0.5	1.5	<0.5	0.78	3.49	0.956	20
09/12/2015	ADP003	7.63	2	1.7	1	0.7	0.84	4.35	1.082	<10
16/12/2015	ADP003	7.97	4	3.3	2	0.6	0.29	4.64	0.462	<10
23/12/2015	ADP003	7.74	8.7	5.9	7.4	1.1	0.84	2.83	0.572	150
30/12/2015	ADP003	7.53	13	4.3	2.6	5.2	0.854	5.431	0.925	<10
06/01/2016	ADP003	7.47	0.5	0.3	1.4	<0.5	0.883	3.676	0.656	<10
13/01/2016	ADP003	7.59	4	3.2	1	5.1	0.83	4.26	0.442	30
20/01/2016	ADP003	8.11	6	5.6	3.4	3.8	0.57	3.423	0.401	10



SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
27/01/2016	ADP003	7.61	0.5	<0.5	1	<0.5	0.75	4.45	0.943	<10
03/02/2016	ADP003	7.68	6.5	5.2	1.3	3.4	0.961	6.103	0.726	<10
10/02/2016	ADP003	7.66	2	1	0.8	3.4	0.82	5.48	0.597	<10
17/02/2016	ADP003	7.78	2	0.6	1.1	3.1	0.23	5.15	0.251	<10
24/02/2016	ADP003	7.61	3	1.5	1.2	3.3	0.27	3.87	0.288	10
02/03/2016	ADP003	7.22	2	1.2	2.3	2.4	1.21	3.58	0.99	36000
09/03/2016	ADP003	7.25	2.5	1.8	2.4	2.8	0.668	2.43	1.07	54000
16/03/2016	ADP003	7.73	3	2.2	1	<0.5	0.381	4.47	0.809	<10
23/03/2016	ADP003	7.56	1	0.4	1.4	2	0.384	3.78	0.393	20
30/03/2016	ADP003	7.89	5.5	4.9	1.4	1.2	0.343	4.99	0.293	<10
06/04/2016	ADP003	7.68	<0.5	<0.5	1.2	4.6	0.524	4.37	0.988	<10
13/04/2016	ADP003	7.73	3	2.5	0.9	2.1	0.241	4.18	0.391	<10
20/04/2016	ADP003	7.74	2	<0.5	2.1	2.3	0.426	2.97	0.242	10
27/04/2016	ADP003	7.44	2.5	1.8	1.3	0.8	1.3	4.73	0.913	<10
04/05/2016	ADP003	7.49	3.5	2.9	1.2	1.9	0.474	4	0.363	<10
11/05/2016	ADP003	7.5	5	4.7	2	1.9	0.784	4.35	0.779	<10
18/05/2016	ADP003	7.59	1	<0.5	1.4	2.1	0.25	4.82	0.705	<10
28/05/2016	ADP003	7.68	3.5	2.4	7.2	1	0.284	3.42	0.418	54000
01/06/2016	ADP003	7.61	3.5	3.3	1.4	3	0.16	6.12	0.18	<10
08/06/2016	ADP003	7.57	2	0.8	2.2	1.2	0.734	7.76	0.633	<10
15/06/2016	ADP003	7.59	5.5	4.2	2.3	1.6	0.223	8.62	0.584	10
22/06/2016	ADP003	7.47	1	<0.5	1.8	<0.5	0.252	5.68	0.703	<10
29/06/2016	ADP003	7.51	<0.5	<0.5	2	2.5	0.298	9.75	1.19	<10
06/07/2016	ADP003	7.64	2.5	1.8	1.1	1.8	0.171	6.53	0.639	<10
13/07/2016	ADP003	7.5	0.5	<0.5	1.2	3	0.268	8.53	0.935	<10
20/07/2016	ADP003	7.64	2	1.2	2.2	0.7	0.225	5.41	0.416	20
27/07/2016	ADP003	7.64	4	1.9	1.4	1.2	0.343	7.36	0.757	70

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
03/08/2016	ADP003	7.55	4	2.2	1.53	5.2	0.634	6.46	1.03	<10
10/08/2016	ADP003	7.54	1	<0.5	2.2	2.8	0.215	8.7	0.713	<10
17/08/2016	ADP003	7.36	<0.5	<0.5	1.7	<0.5	0.479	7.98	1.13	40
24/08/2016	ADP003	7.49	6.5	5.9	3	6.7	0.415	7.21	1.43	800
31/08/2016	ADP003	7.44	5.5	4.3	2	2.4	0.242	7.8	0.518	300
07/09/2016	ADP003	7.6	4.5	3.8	3	3.8	0.338	5.43	0.435	1080
14/09/2016	ADP003	7.44	1.5	1.4	3	1.9	0.748	8.77	1.39	10
21/09/2016	ADP003	7.53	1.5	<0.5	1.17	4.2	0.18	4.77	0.156	20
28/09/2016	ADP003	7.38	5.5	5	6.57	6.7	0.444	7.07	0.526	230
05/10/2016	ADP003	7.41	1.5	0.8	1	<0.5	0.357	8.76	1.21	<10
12/10/2016	ADP003	7.49	1.5	1.3	1.3	3.4	0.167	6.01	0.475	<10
19/10/2016	ADP003	7.44	1	<0.5	1.9	2.7	0.158	8.26	0.15	330
26/10/2016	ADP003	7.54	4	2	2.5	2.9	0.272	6.08	0.475	110
02/11/2016	ADP003	7.61	4	3	2.6	6.1	0.2	7.51	0.542	60
09/11/2016	ADP003	7.65	7	5.9	1.5	4.6	0.244	7.78	0.391	550
16/11/2016	ADP003	7.48	1.5	<0.5	1.8	2.2	0.325	9.34	0.7	120
23/11/2016	ADP003	7.58	3.5	1.5	1.4	5.6	0.366	8.35	0.487	50
30/11/2016	ADP003	7.73	4.5	3.4	1.7	1.2	0.897	7.39	0.956	600
07/12/2016	ADP003	7.61	0.5	<0.5	1.5	1.5	0.478	4.91	0.436	20
14/12/2016	ADP003	7.78	2.5	1.5	0.9	2.8	0.641	7.28	0.776	<10
21/12/2016	ADP003	7.67	6	5.4	1.2	7.7	0.513	6.81	0.74	50
28/12/2016	ADP003	7.43	1	<0.5	1	<0.5	0.749	7.93	1.211	<10
04/01/2017	ADP003	7.17	4	<0.5	0.7	<0.5	2.352	5.572	0.266	30
11/01/2017	ADP003	7.52	1.5	<0.5	1.1	2.4	0.517	8.112	0.647	30
18/01/2017	ADP003	7.78	<0.5	<0.5	0.6	3.1	0.974	4.69	0.295	40
25/01/2017	ADP003	7.49	<0.5	<0.5	0.9	3	0.168	7	0.33	<10
01/02/2017	ADP003	7.5	2.5	<0.5	0.7	1	0.145	5.12	0.296	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
08/02/2017	ADP003	7.53	3	<0.5	1.1	4.2	0.195	7.28	0.487	<10
15/02/2017	ADP003	7.5	2	<0.5	1	0.9	0.203	7.46	0.58	<10
22/02/2017	ADP003	7.51	7.5	5.4	0.7	<0.5	0.164	4.52	0.257	10
01/03/2017	ADP003	7.41	0.5	<0.5	1	1.2	0.191	4.52	0.565	<10
08/03/2017	ADP003	7.52	0.5	<0.5	1.1	2.7	0.21	6.73	0.813	<10
15/03/2017	ADP003	7.47	6.5	3.6	1.9	<0.5	0.488	4.04	0.915	400
22/03/2017	ADP003	7.09	1	<0.5	1.1	2.9	1.08	6.69	0.628	<10
29/03/2017	ADP003	7.31	1	<0.5	1.2	0.3	0.736	7.03	0.91	<10
05/04/2017	ADP003	7.26	21.5	20.3	5.5	1.4	0.531	4.84	0.936	50
12/04/2017	ADP003	7.39	1.5	<0.5	2.9	3.2	0.249	8.998	1.234	50
19/04/2017	ADP003	7.41	2	0.7	1.5	3.5	0.146	8.27	0.657	10
26/04/2017	ADP003	7.45	3	<0.5	2.5	1.1	0.228	8.03	0.919	30
03/05/2017	ADP003	7.57	2	0.1	2	2.7	0.167	5.31	0.623	<10
10/05/2017	ADP003	7.47	0.5	<0.5	1.6	0.7	0.16	8.62	0.526	<10
17/05/2017	ADP003	7.38	<0.5	<0.5	2.5	<0.5	0.235	9.72	0.776	10
24/05/2017	ADP003	7.59	2	0.3	2	1.4	0.226	7.08	0.515	<10
31/05/2017	ADP003	7.63	0.5	<0.5	1.3	<0.5	0.594	4.54	0.62	<10
07/06/2017	ADP003	7.86	1.5	<0.5	3.2	1.4	0.397	10.2	0.628	<10
14/06/2017	ADP003	6.99	11	8.5	2.7	2.4	1.24	3.6	0.376	<10
21/06/2017	ADP003	7.24	3	0.9	1.7	1.1	0.229	4.15	0.344	<10
28/06/2017	ADP003	7.43	1.5	<0.5	<1.0	<0.5	0.112	6.64	0.374	<10
05/07/2017	ADP003	7.49	2.5	1.6	1.9	1.3	0.346	6.4	4.23	10
12/07/2017	ADP003	7.61	3	<0.5	1.2	1.3	0.159	7.65	0.449	<10
19/07/2017	ADP003	7.65	2	0.7	0.7	0.6	0.279	7.69	0.565	190
26/07/2017	ADP003	7.58	3	1.7	1.4	1	0.189	7.64	0.549	<10
02/08/2017	ADP003	7.52	3	<0.5	1.3	2.8	0.171	8.83	0.815	1030
09/08/2017	ADP003	7.56	2.5	<0.5	1.6	0.8	0.187	8.03	0.534	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
16/08/2017	ADP003	7.62	3.5	<0.5	2.5	<0.5	0.326	7.37	0.444	990
23/08/2017	ADP003	7.51	10	<0.5	2.7	<0.5	0.46	8.9	1.3	<10
30/08/2017	ADP003	7.67	13.5	<0.5	3.6	2.8	0.553	9.31	0.9	<10
06/09/2017	ADP003	7.59	3.5	0.7	1.4	1.4	0.334	7.54	0.426	<10
13/09/2017	ADP003	7.67	10.5	<0.5	2.9	2.2	0.845	8.12	0.847	<10
20/09/2017	ADP003	7.95	1	<0.5	1	1	0.473	7.11	0.371	10
27/09/2017	ADP003	7.77	5	<0.5	6.1	2.1	0.378	6.79	0.341	<10
04/10/2017	ADP003	7.51	3.5	<0.5	3.3	<0.5	0.57	5.95	0.467	10
11/10/2017	ADP003	7.6	3.5	2	1.3	0.9	1.04	6.41	0.345	<10
18/10/2017	ADP003	7.17	2.5	<0.5	2.2	2.4	0.522	4.28	0.023	60
25/10/2017	ADP003	7.16	2.5	<0.5	1.6	<0.5	0.322	7.46	0.648	10
01/11/2017	ADP003	7.62	4.5	<0.5	2.7	1	0.251	8.8	0.275	260
08/11/2017	ADP003	7.54	4	<0.5	2.1	1	0.202	7.59	0.616	240
15/11/2017	ADP003	7.7	4.5	<0.5	1.6	2.9	0.195	7.81	0.342	10
22/11/2017	ADP003	7.55	4.5	<0.5	1.7	1.6	0.154	8.35	0.328	<10
29/11/2017	ADP003	7.51	1.5	<0.5	5.5	1.7	0.338	6.89	1.04	10
06/12/2017	ADP003	7.53	3.5	1.3	0.8	1.2	0.171	4.99	0.515	370
13/12/2017	ADP003	7.6	4	<0.5	1.2	2	0.199	6.07	0.312	<10
20/12/2017	ADP003	7.63	1	<0.5	1.7	3.4	0.302	5.34	0.491	<10
27/12/2017	ADP003	7.69	1	<0.5	1.4	8.3	0.269	4.428	0.648	<10
03/01/2018	ADP003	7.51	2	<0.5	0.7	2.6	0.588	2.221	0.256	<10
10/01/2018	ADP003	7.78	3	<0.5	1.3	<0.5	0.486	5.977	0.451	340
17/01/2018	ADP003	7.75	4	3.1	1.4	5.5	0.242	5.61	0.005	30
24/01/2018	ADP003	7.74	3	0.8	3	4.8	0.477	6.43	0.393	70
31/01/2018	ADP003	7.64	1.5	<0.5	1.2	1	0.54	6.24	4.388	<10
07/02/2018	ADP003	7.59	1.5	<0.5	1	2.2	0.342	4.82	0.275	150
14/02/2018	ADP003	6.98	2.5	<0.5	1.5	4.7	0.601	6.19	0.277	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
21/02/2018	ADP003	7.81	2.5	<0.5	2.1	4	0.525	2.75	0.283	20
28/02/2018	ADP003	7.46	1.5	0.5	<1	0.8	0.533	4.92	0.788	<10
08/03/2018	ADP003	7.35	4.5	2.5	1.4	3.6	0.77	2.93	0.374	<10
15/03/2018	ADP003	7.62	8	4.7	1.1	<0.5	0.462	5.62	0.336	140
22/03/2018	ADP003	7.75	5.5	<0.5	1.2	5.8	0.273	10.4	0.444	300
29/03/2018	ADP003	7.54	2	1	0.6	<0.5	0.509	6.76	0.773	<10
05/04/2018	ADP003	7.59	3	1.9	1	0.8	0.373	8.02	0.78	10
12/04/2018	ADP003	7.73	1.5	<0.5	1.1	0.9	0.275	9.96	0.778	<10
19/04/2018	ADP003	7.7	1	<0.5	1	1.5	0.168	5.3	0.566	<10
26/04/2018	ADP003	7.62	1	<0.5	2.1	0.9	0.404	7.05	0.689	<10
03/05/2018	ADP003	7.65	7.5	5.8	1.2	1.3	0.44	8.63	1.04	10
10/05/2018	ADP003	7.66	3	<0.5	1.6	2.6	0.473	11	1.08	<10
17/05/2018	ADP003	7.76	1.5	0.2	1.2	3	0.205	6.38	0.436	<10
24/05/2018	ADP003	7.73	0.5	<0.5	5.6	4.7	0.267	7.65	0.784	<10
31/05/2018	ADP003	7.64	5.5	4.2	4.1	0.6	0.274	4.19	0.261	<10
07/06/2018	ADP003	7.63	6.5	4	3	2.5	0.457	6	1.34	5400
14/06/2018	ADP003	7.71	1.5	0.3	1.7	2.6	0.206	7.55	0.475	<10
21/06/2018	ADP003	7.69	2.5	<0.5	2.2	0.5	0.329	8.24	0.411	980
28/06/2018	ADP003	7.75	4.5	2.2	1.7	1.6	0.702	13.1	0.343	70
05/07/2018	ADP003	7.56	2.5	<0.5	1.6	1.9	0.368	6.84	0.762	10
12/07/2018	ADP003	7.71	6.5	0.5	2	0.5	0.356	8.43	0.397	10
19/07/2018	ADP003	7.57	2	0.7	1.62	1.2	0.286	9.02	0.476	10
26/07/2018	ADP003	7.64	11.5	9.9	4.2	1.2	0.465	7.51	0.437	40
02/08/2018	ADP003	7.67	14.5	11	4.9	3.4	0.557	10.3	0.437	180
09/08/2018	ADP003	7.71	3.8	2.3	3.5	5.1	0.349	8.76	0.444	410
16/08/2018	ADP003	7.7	0.5	0.3	1	1.2	0.306	8.31	0.612	<10
23/08/2018	ADP003	7.69	4.5	3.9	2.1	3.2	1.05	5.72	1.42	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
30/08/2018	ADP003	7.56	0.5	0.3	0.9	1.8	0.729	7.08	1.12	<10
06/09/2018	ADP003	7.54	2.5	1.9	0.9	2.9	0.211	3.88	0.431	10
13/09/2018	ADP003	7.57	3	0.4	1.9	5.3	0.356	4.26	0.488	<10
20/09/2018	ADP003	7.66	2	<0.5	2	2	0.444	6.01	1.41	130
27/09/2018	ADP003	7.69	5.5	0.4	3.6	1.7	0.757	9.8	1.44	80
04/10/2018	ADP003	7.58	2.5	1.2	1	1.5	0.191	4.89	0.404	<10
11/10/2018	ADP003	7.29	20	18.3	3.2	3.1	0.212	2.72	1.16	13800
18/10/2018	ADP003	7.34	8	6.3	2.7	2.2	0.606	3.06	0.373	40
25/10/2018	ADP003	7.61	5.5	1.8	1.2	<0.5	0.216	4.92	0.353	70
01/11/2018	ADP003	7.54	5.5	<0.5	1.8	13.1	0.186	5.36	0.328	800
08/11/2018	ADP003	7.61	3	0.3	1.1	12	0.192	7.07	0.68	<10
15/11/2018	ADP003	7.63	1.5	<0.5	1.2	<0.5	0.15	6.5	0.564	<10
22/11/2018	ADP003	7.7	6	3.3	1.5	0.9	0.18	5.76	0.38	120
29/11/2018	ADP003	7.71	8	1.3	2.2	1.1	0.21	8.08	0.545	700
06/12/2018	ADP003	7.71	4.5	<0.5	1.7	<0.5	0.192	7.12	0.342	310
13/12/2018	ADP003	7.67	4	1.8	3.1	3.3	0.21	8.36	0.449	1650
21/12/2018	ADP003	7.78	3.5	2.2	2.3	<0.5	0.313	7.68	0.526	<10
27/12/2018	ADP003	6.93	25	3.1	6.1	2.2	0.817	8.94	0.985	80
03/01/2019	ADP003	7.66	3	2.2	1.9	1.9	0.74	8.17	1.08	10
10/01/2019	ADP003	7.67	0.5	<0.5	1.2	<0.5	0.837	8.04	1.321	<10
17/01/2019	ADP003	7.76	0.5	<0.5	1.4	1	0.621	5.52	0.933	30
24/01/2019	ADP003	7.74	<0.5	<0.5	2.7	<0.5	0.647	6.13	0.774	120
31/01/2019	ADP003	8.26	<0.5	<0.5	1.5	0.7	0.731	8.37	1.583	20
07/02/2019	ADP003	7.76	3.3	2	1.4	<0.5	0.669	5.34	0.91	20
14/02/2019	ADP003	8	5.3	2.8	1	0.6	0.588	5.6	0.793	20
21/02/2019	ADP003	7.82	5	2.9	3.3	1.2	0.633	6.06	0.738	310
28/02/2019	ADP003	7.93	8.5	4.1	2.1	<0.5	0.821	6.2	0.821	400

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
07/03/2019	ADP003	7.77	<0.5	<0.5	2.1	1.1	0.813	7.232	1.04	800
14/03/2019	ADP003	7.89	5.3	2.6	5.4	<0.5	2.73	16.4	11.43	108000
21/03/2019	ADP003	7.57	4	<0.5	5.8	6.3	3.78	9.43	4.609	36000
28/03/2019	ADP003	7.59	1.5	1.1	1.5	1.2	0.344	6.22	1.063	700
04/04/2019	ADP003	7.52	1.5	0.9	3.3	0.8	0.775	4.68	1.35	500
11/04/2019	ADP003	7.78	1	<0.5	2.1	1.7	1.04	7.28	1.48	80
18/04/2019	ADP003	7.54	<0.5	<0.5	1.5	1.8	0.651	11.4	2.08	20
24/04/2019	ADP003	7.48	0.5	<0.5	1.9	4.8	0.762	9.52	2.07	90
02/05/2019	ADP003	7.77	4	3.2	2.6	0.8	0.414	7.88	0.808	3400
08/05/2019	ADP003	7.66	1	<0.5	1.3	1	0.59	7.98	1.57	80
15/05/2019	ADP003	7.57	0.7	0.2	1.9	<0.5	0.319	6.21	0.797	900
22/05/2019	ADP003	7.48	1.5	0.8	1.8	1.3	0.644	9	1.77	<10
29/05/2019	ADP003	7.73	3.3	2.7	1.7	2	0.449	6.56	2.96	1400
05/06/2019	ADP003	7.6	15	4.4	5.4	<0.5	0.68	6.63	1.84	10
12/06/2019	ADP003	7.76	2	0.9	3.5	1.9	0.598	8.24	6.96	100
19/06/2019	ADP003	7.61	2	1.1	1.1	1.4	0.241	5.57	0.727	<10
26/06/2019	ADP003	7.23	10.5	8.9	4.8	1.1	0.393	4.38	0.98	480
03/07/2019	ADP003	7.51	<0.5	<0.5	2.4	2.6	0.415	7.87	2.36	<10
10/07/2019	ADP003	7.58	1.5	0.5	2.3	<0.5	0.572	9.01	4.37	<10
17/07/2019	ADP003	7.7	5	4.6	2.2	2	0.299	9.18	1.07	90
24/07/2019	ADP003	7.69	0.5	0.4	2.7	<0.5	0.633	10.1	4.27	50
31/07/2019	ADP003	7.81	24	16.4	8.5	2.2	0.816	18	12.4	120
07/08/2019	ADP003	7.54	3.3	2.8	2.1	<0.5	0.519	6.81	2.24	<10
14/08/2019	ADP003	7.61	6	5.4	2.2	<0.5	0.323	5.5	0.704	<10
21/08/2019	ADP003	7.52	2	0.9	3.5	2	1.02	9.89	4.64	700
28/08/2019	ADP003	7.72	4.7	3.3	2.2	0.7	0.247	8.36	0.769	<10
04/09/2019	ADP003	7.66	2	1.3	2.9	2.4	0.491	7.92	1.81	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
11/09/2019	ADP003	7.6	<0.5	<0.5	2.1	1.9	0.448	8.95	1.55	<10
18/09/2019	ADP003	7.56	3	0.8	3.9	8.4	0.425	10.3	1.61	<10
25/09/2019	ADP003	7.77	1	<0.5	3.2	3.4	0.637	10.1	0.709	150
02/10/2019	ADP003	7.53	3.3	0.6	4.5	2.1	0.469	9.36	1.1	<10
09/10/2019	ADP003	7.45	5	4.5	2.3	5.5	0.202	6.55	0.046	5300
16/10/2019	ADP003	7.44	<0.5	<0.5	3.9	0.7	0.104	7.16	0.091	19000
23/10/2019	ADP003	7.86	22.5	6.8	12	0.8	1.25	7.74	0.646	160
30/10/2019	ADP003	7.7	2.5	2	1.7	0.8	0.652	8.55	1.48	10
06/11/2019	ADP003	7.82	5	<0.5	2.2	1.1	0.389	6.72	0.623	70
13/11/2019	ADP003	7.73	1	<0.5	2.2	0.5	0.65	8.27	1.28	<10
21/11/2019	ADP003	7.91	1.5	<0.5	3.2	2.2	1.44	7.39	1.75	<10
27/11/2019	ADP003	7.76	5	3.6	2.6	3.8	0.415	7.54	0.775	<10
04/12/2019	ADP003	7.51	5	3.5	1.5	3.1	0.311	7.05	0.666	<10
11/12/2019	ADP003	7.83	8	2.2	2.8	1.4	1.16	6.96	1.167	20
18/12/2019	ADP003	7.6	8.5	0.4	0.7	2.6	0.534	6.21	0.693	20
24/12/2019	ADP003	7.59	3.5	2.6	2.5	2.7	0.567	6.32	0.84	<10
02/01/2020	ADP003	7.7	4	<0.5	1.3	0.3	0.947	4.31	0.848	<10
08/01/2020	ADP003	7.57	5	4.4	1.6	1.2	0.821	6.49	0.898	<10
15/01/2020	ADP003	7.55	4	2.2	1.2	3	0.541	7.4	0.92	20
22/01/2020	ADP003	7.4	4	0.4	1.4	2.3	0.545	5.84	0.562	<10
29/01/2020	ADP003	7.48	2.5	<0.5	0.5	3.2	0.454	6.14	0.64	<10
05/02/2020	ADP003	7.48	0.5	<0.5	1.4	1.1	0.655	7.01	1.49	20
12/02/2020	ADP003	7.41	3	2.6	1.1	3.9	0.836	5.7	0.85	150
19/02/2020	ADP003	7.35	0.5	0.3	1.3	2.4	0.699	8.31	1.33	10
26/02/2020	ADP003	7.41	0.5	0.2	2.5	2.6	0.643	4.99	1.16	<10
04/03/2020	ADP003	7.65	4	1.4	2.2	2.8	0.591	10.1	1	2400
11/03/2020	ADP003	7.46	2	<0.5	0.9	5.4	0.394	4.87	0.574	60



SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
18/03/2020	ADP003	7.47	<0.5	<0.5	1	3	0.659	8.78	1.19	80
25/03/2020	ADP003	7.55	1.5	0.5	1.1	2.1	0.45	7.62	0.761	410
01/04/2020	ADP003	7.52	4	2.5	1.2	4.8	0.487	9.3	1.1	560
08/04/2020	ADP003	7.64	<0.5	<0.5	2	2	1.06	9.84	2.37	<10
15/04/2020	ADP003	7.68	3	0.8	1.6	2.3	0.655	7.65	0.99	<10
22/04/2020	ADP003	7.75	0.7	<0.5	1.9	3.3	0.864	9.57	1.85	<10
29/04/2020	ADP003	7.51	1	0.4	1.7	1.1	0.532	8.37	1.52	<10
06/05/2020	ADP003	7	7	0.9	3.5	4.8	0.542	9.17	1.47	190
13/05/2020	ADP003	7.71	8	<0.5	2.8	2.4	0.716	10.3	1.48	820
20/05/2020	ADP003	7.74	3	1.4	2.5	1.8	0.616	8.63	2.42	<10
27/05/2020	ADP003	7.6	6.7	4.4	2	3.5	0.284	8.46	0.62	30
03/06/2020	ADP003	7.61	3	0.8	1.8	0.9	0.37	7.18	0.741	<10
10/06/2020	ADP003	7.69	3	1.6	2.1	1	0.39	8.41	1.09	10
17/06/2020	ADP003	7.49	3	1.2	1.7	6.3	0.69	10.3	1.805	<10
24/06/2020	ADP003	7.5	3	2	2.8	3.9	0.37	7.41	1.07	10
01/07/2020	ADP003	7.56	2	0.8	1.6	4.8	0.54	7.6	1.24	20
08/07/2020	ADP003	7.55	4	3	1.5	0.5	0.82	9.17	2.62	<10
15/07/2020	ADP003	7.63	3	2.1	3.7	1.7	0.435	9.11	0.889	650
22/07/2020	ADP003	7.06	5	3.4	4	1.7	0.509	6.67	0.809	140
29/07/2020	ADP003	7.53	2	1.4	2.3	1.7	0.43	7.11	1.71	<10
05/08/2020	ADP003	7.72	13	<0.5	10	8.8	1.86	11.6	4.89	510
12/08/2020	ADP003	7.65	5	3.5	5.3	0.8	0.86	14	7.94	280
19/08/2020	ADP003	7.58	6	4.8	6.6	1	0.524	8.25	0.808	220
26/08/2020	ADP003	7.6	10	8.6	8.7	5.2	0.74	11.1	1.19	90
02/09/2020	ADP003	7.57	4	2.5	7.1	10.4	0.738	8.95	1.23	260
09/09/2020	ADP003	7.55	3	2	4.3	1.6	1	9.84	3.81	<10
16/09/2020	ADP003	7.72	10	3.3	1.2	5.6	1.12	8.76	1.72	840

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
23/09/2020	ADP003	7.55	2	0.5	2.2	4	0.55	7.72	1.77	<10
30/09/2020	ADP003	7.65	3	1.3	4.6	4.1	0.46	8.61	1.08	390
07/10/2020	ADP003	7.61	5	3	2.9	3.2	0.576	8.73	1.17	220
14/10/2020	ADP003	7.68	2	1.4	2.4	3.8	0.452	9.89	1.37	<10
21/10/2020	ADP003	7.56	5	2.9	3.4	1.6	1.04	8.34	3.47	190
28/10/2020	ADP003	7.54	5	2.9	5.3	2.3	1.14	6.33	3.44	780
04/11/2020	ADP003	7.88	11	<0.5	3.9	1.5	0.74	8.22	0.999	1600
11/11/2020	ADP003	7.56	1	<0.5	2.2	0	0.77	6.68	2.42	<10
18/11/2020	ADP003	7.73	7	4.7	2	1.2	0.45	5.82	0.797	140
25/11/2020	ADP003	7.84	4	3.3	2.9	3.2	0.527	8.431	1.05	90
02/12/2020	ADP003	7.66	1	0.4	2.4	6.1	0.605	6.65	1.19	10
09/12/2020	ADP003	7.65	2	<0.5	1.9	2.9	0.625	4.2	0.833	<10
16/12/2020	ADP003	7.07	<1	<1	2.4	1	0.542	2.05	0.8	260
23/12/2020	ADP003	7.48	7	5.5	3.2	-	1.03	7.67	1.83	40
30/12/2020	ADP003	7.33	13	11.3	8.76	-	4.64	9.71	8.06	62400
06/01/2021	ADP003	7.36	3	2.4	1.9	2.7	0.914	4.53	2.27	10
13/01/2021	ADP003	7.36	20	19.1	5.4	<0.5	0.964	6.2	1.09	300
20/01/2021	ADP003	7.5	2	1.6	2.4	1.8	0.812	6.51	2.1	60
27/01/2021	ADP003	7.6	4	3.1	2.5	2.6	0.514	9.58	1.14	10
03/02/2021	ADP003	7.73	<1	<1	2.2	2.1	0.525	8.37	1.23	10
10/02/2021	ADP003	7.74	3	2	2.3	2.8	0.558	9.45	1.54	<10
17/02/2021	ADP003	7.4	5	4.6	3.9	1.4	0.45	5.31	1.72	<10
24/02/2021	ADP003	7.23	9	8.1	10	1.2	4.37	10.1	8.12	420
03/03/2021	ADP003	7.56	8	6.6	2.1	0	0.76	7.29	1.49	110
10/03/2021	ADP003	7.47	2	1.2	2.7	4.2	0.67	7.6	1.69	10
17/03/2021	ADP003	7.36	1	0.4	1.7	0.8	0.431	5.16	1.06	1060
24/03/2021	ADP003	7.17	8	7.7	2.5	7.8	0.615	2.98	0.381	410

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
31/03/2021	ADP003	7.55	6	4.7	5.2	1	1.83	12.224	7.631	40
07/04/2021	ADP003	7.24	3	0.1	1.2	4	0.228	4.79	0.582	10
14/04/2021	ADP003	7.35	2	<0.5	1.3	9.6	0.325	10.4	1.28	2000
21/04/2021	ADP003	7.46	2	0.4	1.6	6.8	0.443	10.2	2	10
28/04/2021	ADP003	7.68	21	20.4	20.5	1.6	9.6	23.4	21.1	9100
05/05/2021	ADP003	7.52	4	2.4	1.7	0.8	0.361	11.7	2.08	20
12/05/2021	ADP003	7.53	<1	<1	2	6.9	1.439	11.4	2.27	70
19/05/2021	ADP003	7.69	<1	<1	2.1	0.7	0.382	14.2	3.23	<10
26/05/2021	ADP003	7.53	2	1.4	2.9	2.1	0.314	13.6	1.58	1120
02/06/2021	ADP003	7.48	3	2.3	3.1	1	0.415	11.1	1.69	80
09/06/2021	ADP003	7.49	1	0.6	3.7	4	0.44	8.38	1.31	160
16/06/2021	ADP003	7.5	4	2.9	5.3	2	0.275	7.93	0.924	32400
23/06/2021	ADP003	7.64	3	2.3	5.9	<0.5	0.375	6.81	0.911	39000
30/06/2021	ADP003	7.63	3	1.9	3.6	0.9	0.286	7.86	0.975	10
07/07/2021	ADP003	7.41	4	3	4.1	1.9	0.465	15.8	8.28	20
14/07/2021	ADP003	7.67	3	2.2	4.3	<0.5	0.974	12.7	7.57	<10
21/07/2021	ADP003	7.53	1	0.5	2.9	<0.5	-	-	0.708	180
28/07/2021	ADP003	7.69	1	0.4	2.69	<0.5	0.304	14.2	2.1	140
04/08/2021	ADP003	7.48	3	2.3	8.1	1.5	1.08	6.82	1.62	20
11/08/2021	ADP003	7.58	4	3.4	3.6	1	0.465	10.4	1.98	60
18/08/2021	ADP003	7.62	4	1.4	4.2	4.7	0.456	8.66	1.36	3160
25/08/2021	ADP003	7.44	<1	<1	3.6	0.4	0.832	8.1	2.65	40
01/09/2021	ADP003	7.54	5	3.9	2.5	<0.5	0.606	7.02	0.983	390
08/09/2021	ADP003	7.46	2	1.1	2.9	3.1	0.847	7.82	1.968	10
15/09/2021	ADP003	7.45	6	3.7	3.6	1.4	0.782	7.42	2.02	60
22/09/2021	ADP003	7.49	1	<0.5	2.8	4.2	0.826	7.41	1.69	40
29/09/2021	ADP003	7.57	6	1.5	5.9	4.9	0.488	6.76	0.988	1800

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
06/10/2021	ADP003	7.41	9	6.7	4.5	6.4	0.931	9.33	1.56	10
13/10/2021	ADP003	7.35	2	<0.5	3.8	0.5	0.158	3.74	0.772	5200
20/10/2021	ADP003	7.29	<1	<1	4.2	8.2	0.46	7.31	1.25	70
27/10/2021	ADP003	7.57	7	<0.5	5.3	2.4	0.776	7.99	1.64	790
03/11/2021	ADP003	7.55	1	<0.5	4	<0.5	0.441	10.2	1.83	90
10/11/2021	ADP003	7.57	2	0.1	3.2	1.4	0.353	7.4	0.933	2520
17/11/2021	ADP003	7.48	<1	<1	3.6	<0.5	0.752	9.01	3.45	6500
24/11/2021	ADP003	7.55	3	1.7	1.7	2.2	0.301	6.64	0.809	2320
01/12/2021	ADP003	7.34	4	2.3	4	0.6	0.178	3.49	0.849	1240
08/12/2021	ADP003	7.41	3	<0.5	2.9	3	0.428	9.25	3.27	550
15/12/2021	ADP003	7.8	4	<0.5	3.06	1.3	0.316	11.2	1.57	630
22/12/2021	ADP003	7.6	7	5.6	21.4	1.4	0.63	13.1	3.46	2000
29/12/2021	ADP003	7.34	2	1.1	1.8	<0.5	0.275	6.07	1.52	40
05/01/2022	ADP003	7.32	5	3.2	2.8	0.2	0.203	5.06	1.29	1330
12/01/2022	ADP003	7.36	5	3.2	2.08	0.3	0.605	8.69	1.82	70
19/01/2022	ADP003	7.55	2	1.2	1.8	3.2	0.423	9.84	1.36	570
26/01/2022	ADP003	7.46	1	<0.5	1.89	<0.5	0.7	9.22	1.9	50
02/02/2022	ADP003	7.39	1	<0.5	1.7	1.3	0.208	8.99	0.591	20
09/02/2022	ADP003	7.4	3	0.7	2.1	1.2	0.834	6.2	1.25	2410
16/02/2022	ADP003	7.43	5	4.1	4	<0.5	0.395	7.36	1.25	970
23/02/2022	ADP003	7.38	7	5.3	4.3	0.2	1.14	10.5	3.894	50
02/03/2022	ADP003	<b>Data Unavailable Due To Flooding</b>								
09/03/2022	ADP003									
16/03/2022	Maturation Pond	7.42	42	<0.5	22.9	2.3	2.63	13.8	10.6	15600
23/03/2022	Maturation Pond	7.5	20	<0.5	13.2	<0.5	3.76	22.2	19.8	20800
06/04/2022	Maturation Pond	7.83	30	22.5	16.6	1.3	1.64	8.98	8.83	23400
13/04/2022	Maturation Pond	7.18	35	<0.5	26.3	<0.5	3.13	20.9	13.7	24700

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
20/04/2022	Maturation Pond	7.19	60	<0.5	40	6	3.56	23.4	17.8	26000
27/04/2022	Maturation Pond	7.14	55	<0.5	35.5	2.9	3.2	23.2	17.8	20800
04/05/2022	Maturation Pond	7.24	22	<0.5	27.9	2	3.2	24.6	20.6	7800
	IDEA Tank B Clear	7.16	23	21.6	22.9	..	0.426	10.7	6.8	..
11/05/2022	Maturation Pond	7.23	10	7.1	15.3	3.4	3.57	26.3	7.67	2280
	IDEA Tank B Clear	7.08	15	14.5	18	..	0.387	14.5	11.3	..
18/05/2022	Maturation Pond	7.17	50	46.6	17.8	0.6	1.83	15.39	13.7	110
25/05/2022	Maturation Pond	6.99	12	4.9	7.7	2.3	1.06	5.68	4.33	48000
	IDEA Tank B Clear	6.91	7	5.6	8.5	2.1	0.14	3.96	0.85	54000
01/06/2022	Maturation Pond	7.23	3	<0.5	3.4	0.5	1.27	6.35	4.46	3040
	IDEA Tank B Clear	7.23	18	17.3	11.7	1.3	0.459	5.81	<0.005	35200
08/06/2022	Maturation Pond	7.31	5	<0.5	13.9	3.3	1.22	7.28	5.11	7800
	IDEA Tank B Clear	7.26	1	<0.5	7.7	136.6	0.744	5.56	1.48	13000
15/06/2022	Maturation Pond	7.83	19	<0.5	31.2	0.7	1.7	9	3.24	3900
	IDEA Tank B Clear	7.22	4	1.4	12.6	<0.5	0.22	7.8	0.126	14300
22/06/2022	Maturation Pond	7.96	20	<0.5	13.2	0.6	2.83	9.57	4.46	9100
	IDEA Tank B Clear	7.29	22	16.9	18.6	<0.5	0.545	8.14	2.23	16900
29/06/2022	Maturation Pond	7.77	32	<0.5	13	1.6	2.83	9.45	4.77	10400
	IDEA Tank B Clear	7.34	3	<0.5	4.8	1.2	0.137	6.2	0.058	15600
06/07/2022	Maturation Pond	7.21	14	<0.5	7.9	1.9	1.71	9.499	5.184	32000
	IDEA Tank B Clear	6.91	16	13.2	11.4	0.7	1.108	4.221	2.41	93100
13/07/2022	Maturation Pond	7.83	41	<0.5	11.9	0	2.3	8.09	3.382	5400
	IDEA Tank B Clear	7.29	5	1.9	6	1.9	0.431	5.88	0.796	17600
20/07/2022	Maturation Pond	7.68	35	<0.5	11.5	2.6	2.21	10.5	4.63	3000
	EAST ADP003-TANK	7.18	8	4.6	6.2	1.7	0.605	9.62	1.27	6400
27/07/2022	Maturation Pond	7.2	28	<0.5	16.3	1	2.578	9.039	4.39	9000
	EAST ADP003-TANK	7.15	9	7.3	14.6	0.5	1.456	6.85	1.45	3900

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
03/08/2022	Maturation Pond	7.64	41	<0.5	14.3	3	1.84	8.81	3.83	900
	EAST ADP003-TANK	7.32	5	3.5	6.6	2	0.678	8.22	1.41	52000
10/08/2022	Maturation Pond	8.07	50	<0.5	16.7	1.4	2.48	10.8	2.95	1640
	EAST ADP003-TANK	7.34	3	1.5	5.5	0.1	0.34	5.83	0.44	11700
17/08/2022	East Mat Pond	7.98	51	<0.5	17.9	1.5	3.21	12.1	4.32	2600
	IDEA B Clear	7.38	5	4	9.1	<0.5	0.34	9.1	0.082	3900
24/08/2022	East Mat Pond	7.49	48	<0.5	5.7	1	3.21	12.1	6.15	6500
	IDEA B Clear	7.47	3	2.1	3.8	<0.5	0.34	9.1	0.021	3900
31/08/2022	East Mat Pond	7.41	22	<0.5	13.2	1.8	6.08	14.7	10.8	2480
	IDEA B Clear	7.2	11	8.2	23	<0.5	2.66	8.07	2.81	39000
07/09/2022	East Mat Pond	7.26	24	<0.5	16	1.1	3.73	9.97	6.9	1680
	IDEA B Clear	7.16	11	9.9	18.9	0.3	1.46	8.14	2.19	19500
14/09/2022	East Mat Pond	7.52	51	<0.5	22.8	2.5	3.63	12.1	5.31	1200
	IDEA B Clear	7.39	6	4.1	9.7	<0.5	0.501	6.2	0.345	19500
21/09/2022	East Mat Pond	7.39	70	<0.5	25.2	3.9	3.84	12.1	4.43	1200
	IDEA B Clear	7.21	2	0.9	2	0.1	0.104	5.58	0.051	12480
28/09/2022	East Mat Pond	7.35	18	<0.5	10.1	2	3.672	10.728	7.04	300
	IDEA B Clear	7.3	17	16.1	17.7	2.6	2.05	6.55	2.03	117000
05/10/2022	East Mat Pond	7.33	22	<0.5	16.6	0.6	3.15	11.1	6.63	1560
	IDEA B Clear	7.15	5	1.2	9.3	<0.5	0.58	6.11	0.931	14630
12/10/2022	East Mat Pond	7.5	39	<0.5	36.9	2.5	3.19	10.9	5.29	12800
	IDEA B Clear	7.22	1	<0.5	7.3	0.5	0.201	4.25	0.525	39000
19/10/2022	East Mat Pond	7.72	68	<0.5	19.7	5.3	3.94	10.8	3.26	5300
	IDEA B Clear	7.3	0	<0.5	4.8	2.1	0.127	5.58	0.38	39000
26/10/2022	East Mat Pond (FLOODED)	-	-	-	-	-	-	-	-	-
	IDEA B Clear	7.27	3	2.7	4.9	2.2	0.07	5.13	0.006	9310
02/11/2022	East Mat Pond	7.56	78	<0.5	20.3	<0.5	2.36	9.85	1.26	5000

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
	IDEA B Clear	7.26	3	2.7	6.1	<0.5	0.092	6.67	0.048	2600
09/11/2022	East Mat Pond	8.04	38	<0.5	22.9	0.9	2.2	7.8	1.04	7600
	IDEA B Clear	7.24	11	5.6	9.1	1	0.225	6.54	0.632	7000
16/11/2022	East Mat Pond	7.3	29	<0.5	19.2	4.8	3.43	11.8	5.47	4200
	IDEA B Clear	7.17	9	2.6	10.3	1	0.482	2.7	1.16	39000
23/11/2022	East Mat Pond	7.87	57	<0.5	16	0.8	3.29	12.5	3.69	39000
	IDEA B Clear	7.33	1	<0.5	2	0.7	0.079	4.85	0.074	19200
30/11/2022	East Mat Pond	7.88	49	<0.5	26.1	0.3	3.34	8.56	1.91	7000
	IDEA B Clear	7.3	1	<0.5	3.28	0	0.153	4.66	0.485	39000
07/12/2022	East Mat Pond	7.98	48	<0.5	10.8	1.3	3.02	8.22	1.12	7400
	IDEA B Clear	7.31	6	5	4.62	0.6	0.479	7.62	0.768	39000
14/12/2022	East Mat Pond	7.87	23	<0.5	21.6	0.7	2.32	8.11	2.6	2200
	IDEA B Clear	7.24	20	19.3	12.7	0	1.06	9.39	1.89	6500
21/12/2022	East Mat Pond	9.63	74	<0.5	18.2	2.1	2.21	9.26	0.113	700
	IDEA B Clear	7.23	3	0.3	4.6	1.1	0.144	12	0.066	31200
28/12/2022	East Mat Pond	10.29	58	<0.5	12.8	3.7	1.53	9.61	0.027	20
	IDEA B Clear	7.46	2	<0.5	4.1	0.7	0.155	5.2	0.111	9600
04/01/2023	East Mat Pond	9.76	96	<0.5	11.5	4.2	1.86	9.51	0.076	620
	IDEA B Clear	7.62	4	2	2.8	1	0.108	4.63	0.044	29200
11/01/2023	East Mat Pond	9.77	85	<0.5	10.2	1.3	1.58	7.99	0.146	1000
	IDEA B Clear	7.44	1	<0.5	<1	0	0.068	5.6	0.039	15600
18/01/2023	East Mat Pond	9.28	42	<0.5	11.1	0.9	1.44	6.98	1.05	1320
	IDEA A Clear	7.57	4	3.6	3.97	0.4	0.158	5.04	0.173	24800
25/01/2023	East Mat Pond	8.96	49	<0.5	13.98	1.8	1.88	8.18	1.85	170
	IDEA A Clear	7.3	11	9.5	14.13	2.7	0.556	3.88	0.725	7200
01/02/2023	East Mat Pond	8.22	34	<0.5	17.5	1.8	1.43	6.91	1.1	7000
	IDEA B Clear	7.1	3	1.8	3.49	1.3	0.182	2.96	0.061	13600

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
08/02/2023	East Mat Pond	9.45	50	<0.5	13.3	1	1.78	7.3	0.359	500
	IDEA B Clear	7.29	4	3.1	8.6	0.2	0.088	2.73	0.059	52000
15/02/2023	East Mat Pond	8.98	55	<0.5	15.38	0.75	1.61	7.418	0.583	960
	IDEA B Clear	7.42	1	<0.5	2.86	8.3	0.328	5.572	0.032	65000
22/02/2023	East Mat Pond	9.41	79	<0.5	23.33	1.2	1.64	8.42	0.415	620
	IDEA B Clear	7.52	3	1.8	2.51	1.3	0.132	5.38	0.088	6400
01/03/2023	East Mat Pond	9.19	62	<0.5	18.25	3.4	1.35	6.68	0.381	6500
	IDEA B Clear	7.4	1	<0.5	2.75	3.2	0.082	3.77	0.311	11600
08/03/2023	East Mat Pond	8.61	44	<0.5	8.13	1	2.76	5.69	0.359	3900
	IDEA B Clear	7.33	2	0.6	2.74	1.6	1.48	5.79	0.09	9200
15/03/2023	East Mat Pond	9.04	52	<0.5	9.7	2.1	1.71	8.59	0.072	1640
	IDEA B Clear	7.34	1	<0.5	<1	0.7	0.315	6.4	0.017	19200
22/03/2023	East Mat Pond	8.59	43	<0.5	11.4	1.7	1.59	6.78	0.708	3400
	IDEA B Clear	7.46	0	<0.5	1.96	1.8	0.291	7.64	0.105	39000
29/03/2023	East Mat Pond	8.89	29	<0.5	5.3	1.2	1.27	5.31	0.529	6500
	IDEA B Clear	7.47	3	<0.5	4.9	0.5	0.207	4.79	0.099	19600
05/04/2023	East Mat Pond	9.03	41	<0.5	9.2	0.6	1.13	5.71	0.044	230
	IDEA B Clear	7.5	7	5.9	2.9	1.7	0.836	4.78	0.091	9100
12/04/2023	East Mat Pond	9.69	53	<0.5	11.4	2.1	1.34	6.07	0.093	380
	IDEA B Clear	7.7	7	5.3	3.92	3.4	0.804	5.49	0.033	39000
19/04/2023	East Mat Pond	9.17	47	2.5	12.1	6.2	1.28	6.42	0.175	420
	IDEA B Clear	7.35	2	0.7	4.1	2.7	0.099	6.67	0.135	9800
26/04/2023	East Mat Pond	9.14	51	8.6	14.58	14	1.23	7.45	0.019	840
	IDEA B Clear	7.61	3	2.4	4.55	0	0.522	6.12	0.017	16400
03/05/2023	East Mat Pond	8.87	39	<0.5	7.3	0.7	1.15	7.42	0.03	3900
	East B Clear	7.5	5	2.6	0.4	1	0.339	8.8	0.025	52000
10/05/2023	East Mat Pond	9.33	39	1.6	14.35	1.5	0.933	6.91	0.022	990



SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
	East B Clear	7.4	5	2.6	6.7	0	0.398	9.87	0.165	65000
17/05/2023	East Mat Pond	7.25	34	<0.5	19.2	1.7	0.977	8.03	2.11	52000
	East A Clear	7.05	6	4.9	14.4	0.6	0.435	4.05	0.164	22800
24/05/2023	East Mat Pond	8.74	24	<0.5	7.7	0.1	1.18	6.01	0.069	11200
	East B Clear	7.37	5	3.5	5	0	0.268	4.4	<0.005	39000
31/05/2023	East Mat Pond	8.89	37	<0.5	8.75	1.5	0.946	7.04	0.217	7200
	East B Clear	7.16	4	0.5	2.15	1.7	0.172	8.37	0.359	25600
07/06/2023	East Mat Pond	8.06	26	<0.5	11.9	2.5	1.08	8.16	0.336	900
	East B Clear	7.23	7	5	3.2	1.9	0.198	7.13	0.041	5700
14/06/2023	East Mat Pond	8.24	29	<0.5	10.5	2	0.728	6.31	0.326	800
	East B Clear	7.25	3	1.8	1.8	1.5	0.117	6.14	0.047	30400
21/06/2023	East Mat Pond	8.77	34	<0.5	18.3	0.6	0.864	7.69	0.836	1080
	East B Clear	7.37	3	<0.5	5.98	0	0.176	5.64	0.02	39000
28/06/2023	East Mat Pond	8.99	43	<0.5	14.1	5.8	0.877	8.24	0.204	300
	East B Clear	7.36	2	<0.5	1.93	4.6	0.131	4.67	0.044	39000
05/07/2023	East Mat Pond	7.81	57	<0.5	7.42	1.6	1.09	10.1	1	1580
	East B Clear	7.19	3	1.5	4.56	1.2	0.309	7.46	0.824	65000
12/07/2023	East Mat Pond	8.08	24	<0.5	12.1	1.3	0.872	6.81	1.45	120
	East B Clear	7.4	3	0.6	0.99	0	0.07	4.44	0.039	26000
19/07/2023	East Mat Pond	7.69	26	<0.5	16.3	1.2	0.758	7.12	0.755	290
	East B Clear									
26/07/2023	East ADP 003	7.53	8	#REF!	0.46	1.7	0.222	5.98	0.302	<10
02/08/2023	East ADP 003	7.84	6		0.53	1.8	0.26	6.7	0.178	10
09/08/2023	East ADP 003	7.5	4		0.33	1.3	0.249	7.23	0.133	<10
16/08/2023	East ADP 003	7.69	6		0.12	0.5	0.28	5.22	0.038	10
23/08/2023	East Idea ADP003	7.7	2		1.83	0.9	0.167	4.46	0.032	10
30/08/2023	East Idea ADP003	7.78	6		0.92	1.2	0.271	4.65	0.136	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
06/09/2023	East Idea ADP003	7.56	5		<1	0.4	0.263	8.93	4.56	<10
13/09/2023	East Idea ADP003	7.67	6		1.91	0	0.186	3.89	0.225	<10
20/09/2023	East B Clear	7.66	5		1.5	0	0.226	2.29	0.158	<10
27/09/2023	East B Clear	7.75	6		0.59	0.9	0.307	2.58	0.882	<10
04/10/2023	East B Clear	7.59	5		0.7	1.9	0.222	4.68	0.048	<10
11/10/2023	East ADP003	7.52	14		0.52	0.4	0.573	5.77	0.049	<10
18/10/2023	East ADP003	7.66	16		0.35	0.7	0.611	4.97	0.286	<10
25/10/2023	East Idea ADP003	7.74	6		3.9	2	0.374	5.2	0.408	<10
01/11/2023	East Idea ADP003	7.63	5		0.86	1.2	0.437	4.65	0.076	<10
09/11/2023	East Idea ADP003	7.54	4		3.82	0.6	0.581	5.22	0.743	200
15/11/2023	East Idea ADP003	7.57	5		6.51	1.4	0.537	4.53	0.907	380
22/11/2023	East Idea ADP003	7.37	10		2.91	1.8	0.812	3.67	0.496	30
30/11/2023	East Idea ADP003	7.5	4		0.8	0.3	0.314	5.43	0.375	12
06/12/2023	East Idea ADP003	7.76	7		3.38	0.8	0.0354	5.56	0.168	130
13/12/2023	East Idea ADP003	7.94	6		1.43	1.4	0.184	6.36	0.093	10
20/12/2023	East Idea ADP003	7.8	7		1.34	2.4	0.198	3.86	0.129	<10
27/12/2023	East Idea ADP003	7.55	2		2.58	1.2	0.446	3.61	1.32	<10
04/01/2024	East Idea ADP003	7.84	5		1.88	0	0.301	3.02	0.09	10
10/01/2024	East Idea ADP003	7.9	6		3.95	2.5	0.186	3.57	0.208	10
19/01/2024	East Idea ADP003	7.29	3		0.41	0.4	0.576	4.02	0.368	10
24/01/2024	East Idea ADP003	7.83	3		1.16	2	0.241	4.58	0.113	10
31/01/2024	East Idea ADP003	7.67	3		2.9	6.3	0.43	5.4	0.646	10
07/02/2024	East Idea ADP003	7.79	15		2.19	2.1	0.372	4.92	0.17	30
14/02/2024	East Idea ADP003	7.64	4		0.94	1.1	0.475	5.31	0.135	130
22/02/2024	East Idea ADP003	7.64	20		3.35	1.6	0.857	6.15	0.426	20
28/02/2024	East Idea ADP003	7.6	5		1.54	3.8	0.402	5.92	0.404	<10
06/03/2024	East Idea ADP003	7.79	1		2.19	0.8	0.235	6.3	0.508	<10

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
13/03/2024	East Idea ADP003	7.66	6		3.4	2.3	0.233	5.79	0.679	3
20/03/2024	East Idea ADP003	7.51	5		<1	0.7	0.225	3.54	0.434	1
27/03/2024	East Idea ADP003	7.49	16		2.04	0.9	0.79	3.34	0.243	6
03/04/2024	East Idea ADP003	7.62	7		2.02	3.2	0.385	5.62	0.012	15
10/04/2024	East Idea ADP003	7.41	3		1.49	3.3	0.621	7.5	0.463	70
17/04/2024	East Idea ADP004	7.41	7		3.58	0.8	0.267	6.73	0.078	5
24/04/2024	East IDEA B CLEAR	7.46	5		1.3	3.6	0.234	5.19	0.375	6
01/05/2024	East Idea ADP003	7.68	1		<1	1	0.156	5.16	0.484	5
08/05/2024	East Idea ADP003	7.53	3		<1	0.2	0.123	3.23	0.456	<1
15/05/2024	East Idea ADP003	7.56	5		<1	3.7	0.265	3.87	0.673	4
22/05/2024	East Idea ADP003	7.48	2		0.69	0.8	0.749	5.516	0.35	7
29/05/2024	East Idea ADP003	7.49	2		<1	3	0.13	4.96	0.308	4
05/06/2024	East Idea ADP003	7.63	4		2.17	1.6	0.219	6.12	0.079	6
12/06/2024	East Idea ADP003	7.7	3		<1	0.7	0.215	5.33	0.037	3
19/06/2024	East Idea ADP003	7.72	5		1.2	0.8	0.22	3.32	0.012	1
26/06/2024	East Idea ADP003	7.65	1		1.4	0.7	0.178	3.97	0.125	3
03/07/2024	East Idea ADP003	8.02	11		1.24	5.8	0.257	2.78	0.319	1
10/07/2024	East Idea ADP003	7.39	3		0.91	1	0.522	4.14	0.27	20
17/07/2024	East Idea ADP003	7.4	3		1.16	2.6	0.265	7.88	0.281	5
24/07/2024	East Idea ADP003	7.46	2		1.36	0.7	0.257	6.85	0.599	<1
31/07/2024	East Idea ADP003	7.71	5		1.71	0.3	0.197	3.93	0.127	8
07/08/2024	East Idea ADP003	7.5	6		2.62	5.9	0.586	4.31	1.54	<1
14/08/2024	No Sampling - Flood Mode									
21/08/2024	East Idea ADP003	7.46	5		1.29	1.8	0.884	3.99	0.38	3
28/08/2024	East Idea ADP003	7.62	5		2.34	0.5	0.278	2.13	0.197	4
04/09/2024	East Idea ADP003	7.54	6		3.7	1.2	0.587	4.58	2.53	4
11/09/2024	East Idea ADP003	7.52	5.5		6.2	1.6	0.386	3.74	1.05	<1

SAMPLE DATE	MONITORING POINT	pH	Total Suspended Solids (mg/L)	TSS (corrected for Algae) (mg/L)	B.O.D.5 (mg/L O2)	Total Oils and Grease (mg/L)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Ammonia (NH4+) (mg/L N)	Faecal Coliforms (cfu/100ml)**
18/09/2024	East Idea	7.48	5		2.99	1.6	0.782	5.278	2.96	<1
25/09/2024	East Idea ADP003	7.57	6		4.3	1.2	0.995	4.82	2.66	<1
03/10/2024	East Idea ADP003	7.42	2		0.71	0.8	1.1	5.06	0.353	<10
09/10/2024	East Idea ADP003	7.46	1		0.82	1.3	0.356	7.56	2.78	<10
16/10/2024	East Idea ADP003	7.37	3		1.6	1.5	0.611	4.9	0.598	<1
23/10/2024	East Idea ADP003	7.53	3		2.95	2.9	0.645	5.15	2.57	<1
30/10/2024	East Idea ADP003	7.58	3		1.96	<2	0.239	5.21	0.393	<1
06/11/2024	East Idea ADP003	7.59	13		11.6	2.1	0.687	6.49	2.96	<1
13/11/2024	East Idea ADP003	7.48	5		3.43	5.4	0.252	3.05	0.295	<1
20/11/2024	East Idea ADP003	7.41	5		6.5	<2	0.522	3.54	0.277	20
27/11/2024	East Idea ADP003	7.66	3		2.25	4	0.44	3.12	0.167	6
04/12/2024	East Idea ADP003	7.74	3		<1	<2	0.937	6.57	0.481	<1

EPA Licence Limits								
	pH - Lower Limit	pH - Upper Limit	Total Suspended Solids	BOD	Total Oils and Grease	Total Phosphorus	Total Nitrogen	Ammonia (NH <sub>4</sub> <sup>+</sup> )
90 percentile limit	-	-	20 mg/L	15 mg/L	-	1 mg/L	15 mg/L	5 mg/L
100 percentile limit	6.5	8.5	40 mg/L	35 mg/L	10 mg/L	3 mg/L	25 mg/L	10 mg/L